


Model Number	Nominal Size (inches) W x H	Wire Size (inches) W x H	Number of Cross Wires	Initial Resistance (inches W.G.) 300 FPM 500 FPM
ACT-217	10 x 20	9-1/2 x 19-1/2	1	.17 .35
ACT-210	12 x 24	11-3/8 x 23-3/8	2	.17 .35
ACT-245	15 x 20	14-1/2 x 19-1/2	1	.17 .35
ACT-201	16 x 20	15-1/2 x 19-1/2	1	.17 .35
ACT-216	16 x 24	15-3/8 x 23-3/8	2	.17 .35
ACT-202	16 x 25	15-1/2 x 24-1/2	2	.17 .35
ACT-212	18 x 24	17-3/8 x 23-3/8	2	.17 .35
ACT-261	20 x 16	19-1/2 x 15-1/2	1	.17 .35
ACT-203	20 x 20	19-1/2 x 19-1/2	1	.17 .35
ACT-211	20 x 24	19-3/8 x 23-3/8	2	.17 .35
ACT-204	20 x 25	19-1/2 x 24-1/2	2	.17 .35
ACT-206	24 x 12	23-3/8 x 11-3/8	1	.17 .35
ACT-244	24 x 16	23-3/8 x 15-3/8	1	.17 .35
ACT-215	24 x 20	23-3/8 x 19-3/8	1	.17 .35
ACT-205	24 x 24	23-3/8 x 23-3/8	2	.17 .35
ACT-165	25 x 16	24-1/2 x 15-1/2	1	.17 .35
ACT-252	25 x 20	24-1/2 x 19-1/2	1	.17 .35
ACT-225	25 x 25	24-1/2 x 24-1/2	2	.17 .35

NOTES:

1. MERV 6 ASHRAE 52.2-1999
2. Final Resistance: 1.0" W.G.
3. Filters Classified per U.L. Standard 900 for flammability only
4. Filters Class 2 Filter Per U.L. Standard S111
5. Maximum Operating Temperature: 220 deg. F

STANDARD CONSTRUCTION:

1. Polyester Media With Tack Blended Multi-Denier Media Layer Air Entering Side (White) Needed Media Layer Air Leaving Side (White)
2. Heat Seal Construction
3. 9 GA Steel Internal Wire Frame
4. Cross Wires Installed in the Width Direction

 <p>1612 North Davis Ave. Ottawa, KS 66067 P: 800-624-8739 F: 785-242-8700 www.ati-filters.com</p>		<p>TOLERANCES UNLESS OTHERWISE SPECIFIED</p>	
		<p>FRACTIONAL DECIMAL ANGLES</p>	<p>APPROVED BY: _____ SPECIFICATION NO. MKT-B-00450 REVISION: NEW DATE: 5-14-2012</p>
<p>CONTACT FACTORY TO VERIFY REVISION LEVEL</p>		<p>SCALE: NONE DWG. SIZE: A PAGE: 1 OF 1</p>	<p>CONFIDENTIAL - DO NOT COPY. THIS MATERIAL IS TRADE SECRET AND PROPRIETARY BEING EXCLUSIVELY OWNED BY CJC AIR. THE EXPRESSION OF THE INFORMATION CONTAINED HEREIN IS PROTECTED UNDER FEDERAL COPYRIGHT LAWS AND ALL COPYING IS PROHIBITED AND MAY BE SUBJECT TO CRIMINAL PENALTIES.</p>