

## **ASHRAE STANDARD 62-2001 Ventilation for Acceptable Indoor Air Quality**

### **Air Cleaning Specifications**

Specifies that filters with a MERV Rating of not less than 6 be installed upstream of all cooling coils.

Specifies that gas phase adsorbers (typically activated carbon) be used to control gaseous contaminants when needed to provide an adequate level of indoor air quality.